

Tsurumi Operation Unit - 2



Consumer Confidence Report Drinking Water Systems 2013



Commander, Fleet Activities, Yokosuka


Issued in accordance with Commander, Navy Installation Command Policy Letter 5200, Ser N4/13U84441, 15 Oct 13.
This report reflects monitoring data collected in 2013 and will be updated annually.

The Navy is pleased to provide you with this annual Consumer Confidence Report (CCR) of Drinking Water Systems that support Tsurumi Operation Unit (OU) -2.

This pamphlet provides information about the water delivered to Tsurumi OU-2 in 2013. It describes where our water comes from, what it contains, and how it compares to standards for safe drinking water. The drinking water at Tsurumi OU-2 is safe to drink. Our goal is, and always has been, to provide safe and dependable drinking water.

Source of Water

Drinking water at Tsurumi OU-2 is surface water from the Sagami River purchased from the Yokohama Waterworks Bureau. The waterworks filter and chlorinate the drinking water provided to us. The treatment system used is the conventional "rapid sand filtration system" and is also the most common conventional treat system utilized in the U.S. Water quality information provided by the supplier is regularly monitored.



Legend:

- *1: Sagami Lake, *2: Tsukui Lake, *3: Miyagase Lake,
- *4: Tanzawa Lake, *5: Doushi River, *6: Sagami River,
- *7: Sakawa River, *8: Hashirimizu Spring

Water Distribution Systems

The Naval Facilities Engineering Command (NAVFAC) Far East Public (FE) Works Department (PWD) operates the water distribution system servicing our area. Purchased water is directly distributed throughout Tsurumi OU-2 without any treatment by NAVFAC FE.

Water Quality

This year, as in years past, our drinking water met all criteria established in the Japan Environmental Governing Standards (JEGS), Commander, Navy Installations Command Instruction 5090.1, and applicable parts of the National Primary Drinking Water regulations promulgated under the Safe Drinking Water Act of 1974. The JEGS intent is to ensure DoD activities and installations in Japan protect human health and the natural environment through the promulgation of specific environmental compliance criteria. Our drinking water standards are derived from the same standards used in the U.S. to ensure safe drinking water is available to all installation personnel. They require us to monitor and test our water for contaminants on a regular basis, ensuring it is safe to drink.

Possible Source of Contaminants

As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals. It can also pick up other contaminants resulting from the presence of animals or human activity. Drinking water, including bottled water, may reasonably be expected to contain trace amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency (EPA) Safe Drinking Water Hotline at 1-800-426-4791 or visiting the EPA website at <http://water.epa.gov/drink/>

Potential Contaminants

Lead

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This year, as in years past, our tap water did not exceed the lead drinking water health standards requirements set forth in the JEGS and other applicable regulatory requirements. When your water has been sitting for several hours, you can further minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using the water for drinking or cooking. Information on lead in drinking water is available at <http://water.epa.gov/drink/info/lead/index.cfm>

Nitrate/Nitrite

Nitrates are naturally present in soil, water, and food. They are used primarily to make fertilizer. Nitrates themselves are relatively nontoxic. However, when swallowed, they are converted to nitrites that can react with hemoglobin in the blood, creating methemoglobin. This methemoglobin cannot transport oxygen, causing shortness of breath and blue baby syndrome. This year, as in years past, our tap water did not exceed the Nitrate/Nitrite drinking water health standards requirements set forth in the JEGS and other applicable regulatory requirements. Information on Nitrate in drinking water is available at <http://water.epa.gov/drink/contaminants/basicinformation/nitrate.cfm>

Arsenic

Arsenic is odorless and tasteless. It enters drinking water supplies from natural deposits in the earth or from agricultural and industrial practices. People who over a period of many years drink water contaminated with arsenic in excess of the drinking water standards could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer. This year, as in years past, our tap water did not exceed the arsenic drinking water health standards requirements set forth in the JEGS and other applicable regulatory requirements. Information on Arsenic in drinking water is available at <http://water.epa.gov/drink/contaminants/basicinformation/arsenic.cfm>

Drinking Water Monitoring

We use Japanese and EPA approved laboratory methods to analyze our drinking water. FLEACT Yokosuka monitors its drinking water for the following constituents.

Constituent	Frequency
pH, Conductivity, Turbidity, Chlorine Residue, Water Temperature, and Water Pressure	Real Time Monitoring
Fluoride and Turbidity	Daily
Disinfection byproducts (Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5))	Quarterly
Total Coliform	Monthly
Lead, Copper, Inorganic Chemicals, and Organic Chemicals	Annually
PCBs, Herbicides, and Pesticides	Once every 3 years
Radionuclides	Once every 4 years
Asbestos	Once every 9 years

The table on page three lists constituents detected during the latest round of required sampling. Only those constituents detected are listed. The presence of a contaminant does not necessarily indicate the water poses a health risk. None of the samples exceeded the JEGS and other applicable drinking water health standards. As such, **Tsurumi OU-2's drinking water is safe and fit for human consumption.** The water samples were collected from multiple locations and faucets. For example, for Total Coliform, we monitor 36 locations a month throughout FLEACT Yokosuka with one (1) of the locations being at Tsurumi OU-2. The collected samples are not pooled. They are analyzed individually.

Frequently Asked Questions

Why does the water sometimes look rusty?

Rusty or reddish tinted water may occur when a sudden change in pressure in the water distribution system causes rust in the distribution pipes to become dislodged. Iron causes the discoloration: it is not a health risk. If water looks rusty, flush your tap for several minutes or until water is clear. Running the water will clear the piping system. If hot tap water is rusty, the water heater may need to be flushed.

TSURUMI OU-2 FUEL TERMINAL – DRINKING WATER DETECTED CONSTITUENTS IN 2013

Constituents	Unit of Measure	Detected Level		Standard (AL*/ MCL/ MRDL**)	Violation	Possible Source of Contamination
		High	Low		Yes / No	
INORGANIC CONTAMINANTS						
Barium	mg/L	0.0021	-	2.0	No	Erosion of natural deposits.
Nitrate, Nitrite (as Nitrogen)	mg/L	1.2	-	10	No	Erosion of natural deposits.
Sodium	mg/L	6.8	-	200	No	Erosion of natural deposits.
Lead	mg/L	0.023***	ND	0.015*	No	Corrosion of household plumbing. Erosion of natural deposits.
Copper	mg/L	0.023	ND	1.3*	No	Corrosion of household plumbing. Erosion of natural deposits.
DISINFECTANTS & DISINFECTION BYPRODUCTS						
Residual Chlorine	mg/L	0.79	0.39	4.0**	No	Disinfectant.
Total Trihalomethanes	mg/L	0.019	-	0.08	No	By-product of drinking water chlorination.
Halo Acetic Acids (HAA5)	mg/L	0.013	-	0.06	No	By-product of drinking water chlorination.

Abbreviations and Definitions:

AL: Action Level - The concentration of a contaminant in water that establishes the appropriate treatment for a water system.
 MCL: Maximum Contaminant Level - The highest level of a contaminant allowed in drinking water.
 mg/L: milligrams per Liter.
 MRDL: Maximum Residual Disinfectant Level - The level of a disinfectant added for water treatment measured at the consumer’s tap, which may not be exceeded without the unacceptable possibility of adverse health effects.
 ND: Not Detected.

Notes:

*Lead and Copper - Action Level.
 **Residual Chlorine - Maximum Residual Disinfectant Level.
 ***Additional water quality sample taken and result was ND.

COMFLEACT Yokosuka monitors for many contaminants, only those detected during laboratory analysis are listed above.

Contacts

Installation Water Quality Board

The Installation Commanding Officer has established an Installation Water Quality Board (IWQB) tasked with ensuring there is a reliable supply of drinking water for all persons utilizing FLEACT, Yokosuka facilities.

Installation Water Quality Board

Commander.....	243-7300
Chief Staff Officer.....	243-7301
Public Works Officer.....	243-6046
U.S. Naval Hospital.....	243-2616
Public Affairs Officer.....	243-5607
Public Works Production Officer.....	243-9119
Public Works Environmental Director.....	243-6592

For questions regarding information in this report or on drinking water in general please contact:
 Yoshiaki Kanazawa, COMFLEACT, Yokosuka PWD Environmental Division at DSN 243-6460 or Yoshiaki.Kanazawa.JA@fe.navy.mil