

Table 2. 2016-2023 OLF Coupeville Off-Base Drinking Water Well Sampling Results

Samples	PFOA (ppt)	PFOS (ppt)	PFOA+PFOS (ppt)
1	ND	ND	ND
2	ND	ND	ND
3	ND	ND	ND
4	ND	ND	ND
5	ND	ND	ND
6	ND	ND	ND
7	ND	ND	ND
8	ND	ND	ND
9	ND	ND	ND
10	ND	ND	ND
11	ND	ND	ND
12	ND	ND	ND
13	ND	ND	ND
14	ND	ND	ND
15	ND	ND	ND
16	ND	ND	ND
17	ND	ND	ND
18	ND	ND	ND
19	ND	ND	ND
20	ND	ND	ND
21	ND	ND	ND
22	ND	ND	ND
23	ND	ND	ND
24	ND	ND	ND
25	ND	ND	ND
26	ND	ND	ND
27	ND	ND	ND
28	ND	ND	ND
29	ND	ND	ND
30	ND	ND	ND
31	ND	ND	ND
32	ND	ND	ND
33	ND	ND	ND
34	ND	ND	ND
35	ND	ND	ND
36	ND	ND	ND
37	ND	ND	ND
38	ND	ND	ND
39	ND	ND	ND
40	ND	ND	ND
41	ND	ND	ND
42	ND	ND	ND
43	ND	ND	ND
44	ND	ND	ND
45	ND	ND	ND
46	ND	ND	ND

Table 2. 2016-2023 OLF Coupeville Off-Base Drinking Water Well Sampling Results

Samples	PFOA (ppt)	PFOS (ppt)	PFOA+PFOS (ppt)
47	ND	ND	ND
48	ND	ND	ND
49	ND	ND	ND
50	ND	ND	ND
51	ND	ND	ND
52	ND	ND	ND
53	ND	ND	ND
54	ND	ND	ND
55	ND	ND	ND
56	ND	ND	ND
57	ND	ND	ND
58	ND	ND	ND
59	ND	ND	ND
60	ND	ND	ND
61	ND	ND	ND
62	ND	ND	ND
63	ND	ND	ND
64	ND	ND	ND
65	ND	ND	ND
66	ND	ND	ND
67	ND	ND	ND
68	ND	ND	ND
69	ND	ND	ND
70	ND	ND	ND
71	ND	ND	ND
72	ND	ND	ND
73	ND	ND	ND
74	ND	ND	ND
75	ND	ND	ND
76	ND	ND	ND
77	ND	ND	ND
78	ND	ND	ND
79	ND	ND	ND
80	ND	ND	ND
81	ND	ND	ND
82	ND	ND	ND
83	ND	ND	ND
84	ND	ND	ND
85	ND	ND	ND
86	ND	ND	ND
87	ND	ND	ND
88	ND	ND	ND
89	ND	ND	ND
90	ND	ND	ND
91	ND	ND	ND
92	ND	ND	ND

Table 2. 2016-2023 OLF Coupeville Off-Base Drinking Water Well Sampling Results

Samples	PFOA (ppt)	PFOS (ppt)	PFOA+PFOS (ppt)
93	ND	ND	ND
94	ND	ND	ND
95	ND	ND	ND
96	ND	ND	ND
97	ND	ND	ND
98	ND	ND	ND
99	ND	ND	ND
100	ND	ND	ND
101	ND	ND	ND
102	ND	ND	ND
103	ND	ND	ND
104	ND	ND	ND
105	ND	ND	ND
106	1.8	ND	1.80
107	4.44	ND	4.44
108	2.15	2.5	4.65
109	16.3	29.6	45.9
110	70.9	ND	70.9
111	153	4.36	157
112	236	3.78	240
113	334	1.04	335
114	391	ND	391
115	443	ND	443
116	523	ND	523
117	611	1.37	612
118	660	ND	660

	PFOA and/or PFOS not detected
	PFOA and/or PFOS detected below 70 ppt
	PFOA and/or PFOS detected above 70 ppt

Note: Highest detections shown for each well.